

ADDENDUM NO. 2

01. Project name of the Bidding Document: Supply, Installation, Commissioning, and Maintenance of Pre-Fabricated Package Type Sewerage Treatment Plant for the Girls' Hostel at South Eastern University of Sri Lanka - Oluvil.

02. Bid Reference Number: SEU/SS/NCB/2025/02

03. Date: 16.09.2025

04. Amendment to Technical Specifications and Extension of Bid Submission Deadline

Pursuant to a request received from a prospective bidder, the **Technical Specifications** of the bidding document are hereby amended as follows. This Addendum forms part of the Bidding Documents and modifies the original Bidding Documents issued for the project mentioned above.

I). Amendment to Technical Specifications Section V – Technical Specifications (Pages 62 & 63)

Original Clause:

Bidder should specify the following details for pumps and other equipment related to the plant operation (Bidder can use separate sheets if needed)

- 1.1 Product Brand
- 1.2 Product Model
- 1.2a Product Materials (Plant is preferred FRP)
- 1.3 Country of Origin: Europe / Japan / America / Canada
- 1.4 Country of Manufacturer: Europe / Japan / America / Canada
- 1.5 Manufacturer Authorization: Should be attached
- 1.6 Warranty Period required: Plant (STP) and system - Minimum 10 years, Pumps other electrical equipment - Minimum 3 years

Amended Clause:

Bidder should specify the following details for the **Treatment Plant** (Bidder can use separate sheets if needed)

- 1.1 Product Brand: A reputed brand /product manufactured in the countries of Europe / Japan / America / Canada, or a substantially equivalent brand /product manufactured in another country.
- 1.2 Product Model: *Please Specify*
- 1.2a Product Materials (Plant is preferred FRP)
- 1.3 Country of Origin: *Please Specify*
- 1.4 Country of Manufacturer: *Please Specify*
- 1.5 Manufacturer Authorization: Should be attached
- 1.6 Warranty Period required: Plant (STP) and system - Minimum 10 years, Pumps and other electrical equipment - Minimum 3 years

Include the following clause in the specifications of the Sewerage & Wastewater Pumps (1.7)

- Country of Origin: *Please Specify*
- Country of Manufacturer: *Please Specify*
- Brand Name: **Tsurumi / Wilo/ Zoeller/Homa** or substantially equivalent

II). Extension of Bid Submission Deadline

The deadline for bid submission has been extended as follows:


- **Bid Closing Date and Time:** 2.00 p.m. on 2nd October 2025
- **Bid Opening Date and Time:** 2.30 p.m. on 2nd October 2025

05. Additional Documents Provided

The following documents have been added as part of the bidding documents:

- Updated Technical Specifications – Annex I

All bidders are requested to acknowledge the receipt of this Addendum.


Deputy Bursar
Stores and Supplies Division

Deputy Bursar
Stores and Supplies Division
South Eastern University of Sri Lanka
University Park, Olivil # 32300